

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

463 OCEAN TERRACE OWNERS, INC.
ENE 2650 OCEAN PARKWAY
1/2-1 BROOKLYN, NY 11235

NY LTANKS U001835884
NY UST N/A

0.727 mi.
3840 ft.

Relative:
Higher

Actual:
9 ft.

LTANKS:

Name: OCEAN TERRACE CO-OP
Address: 2650 OCEAN PARKWAY
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 9807154 / 1998-10-07
Facility ID: 9807154
Site ID: 105014
Spill Date: 1998-09-10
Spill Cause: Tank Overfill
Spill Source: Institutional, Educational, Gov., Other
Spill Class: C3
Cleanup Ceased: Not reported
SWIS: 2401
Investigator: SMSANGES
Referred To: Not reported
Reported to Dept: 1998-09-11
CID: 384
Water Affected: Not reported
Spill Notifier: Other
Last Inspection: Not reported
Recommended Penalty: False
Meets Standard: False
UST Involvement: False
Remediation Phase: 0
Date Entered In Computer: 1998-09-11
Spill Record Last Update: 1998-11-16
Spiller Name: WALTER BRINGSLID
Spiller Company: OCEAN TERRACE CO-OP
Spiller Address: 2650 OCEAN PARKWAY
Spiller County: 001
Spiller Contact: WALTER BRINGSLID

Spiller Phone: (718) 646-0133
Spiller Extention: Not reported
DEC Region: 2
DER Facility ID: 92696
DEC Memo: "Prior to Sept, 2004 data translation this spill Lead_DEC Field was SANGESLAND "
Remarks: "GAUGE READ WRONG CAUSING OVERFILL"

All Materials:

Site ID: 105014
Operable Unit ID: 1064766
Operable Unit: 01
Material ID: 318268
Material Code: 0001A
Material Name: #2 fuel oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Oxygenate: Not reported

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

UST:

Name: OCEAN TERRACE OWNERS, INC.
Address: 2650 OCEAN PARKWAY
City,State,Zip: BROOKLYN, NY 11235
Id/Status: 2-286869 / Active
Program Type: PBS
Region: STATE
DEC Region: 2
Expiration Date: 08/24/2022
UTM X: 587425.41689
UTM Y: 4493250.97266
Site Type: Apartment Building/Office Building

Affiliation Records:

Site Id: 12812
Affiliation Type: Facility Owner
Company Name: OCEAN TERRACE OWNERS INC.
Contact Type: MANAGING AGENT
Contact Name: NICHOLAS DUBOVICI
Address1: 2650 OCEAN PKWY
Address2: Not reported
City: BROOKLYN
State: NY
Zip Code: 11235
Country Code: 001
Phone: (718) 676-9139
EMail: Not reported
Fax Number: Not reported
Modified By: MFLEONAR
Date Last Modified: 2017-09-28

Site Id: 12812
Affiliation Type: Mail Contact
Company Name: C/O OCEAN TERRACE OWNERS
Contact Type: Not reported
Contact Name: FSR COMPLIANCE
Address1: 622 THIRD AVENUE
Address2: 14TH FLOOR
City: NEW YORK
State: NY
Zip Code: 10017
Country Code: 001
Phone: (212) 634-8900
EMail: COMPLIANCE.NY@FSRESIDENTIAL.COM
Fax Number: Not reported
Modified By: MFLEONAR
Date Last Modified: 2017-09-28

Site Id: 12812
Affiliation Type: Facility Operator
Company Name: OCEAN TERRACE OWNERS, INC.
Contact Type: Not reported
Contact Name: NELSON TRAVINO
Address1: Not reported
Address2: Not reported
City: Not reported
State: NN
Zip Code: Not reported
Country Code: 001
Phone: (718) 646-9139

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

EMail: Not reported
Fax Number: Not reported
Modified By: KAKYER
Date Last Modified: 2012-09-20

Site Id: 12812
Affiliation Type: Emergency Contact
Company Name: OCEAN TERRACE OWNERS INC.
Contact Type: Not reported
Contact Name: NICHOLAS DUBOVICI
Address1: Not reported
Address2: Not reported
City: Not reported
State: NN
Zip Code: Not reported
Country Code: 999
Phone: (212) 634-8900
EMail: Not reported
Fax Number: Not reported
Modified By: MFLEONAR
Date Last Modified: 2017-09-28

Tank Info:

Tank Number: 001
Tank ID: 16614
Tank Status: In Service
Material Name: In Service
Capacity Gallons: 20000
Install Date: 01/14/1993
Date Tank Closed: Not reported
Registered: True

Tank Location: Underground
Tank Type: Steel/carbon steel
Material Code: 0003
Common Name of Substance: #6 Fuel Oil (On-Site Consumption)

Tightness Test Method: 21
Date Test: 08/18/2005
Next Test Date: Not reported
Pipe Model: Not reported
Modified By: MFLEONAR
Last Modified: 09/28/2017

Equipment Records:

E00 - Piping Secondary Containment - None
I02 - Overfill - High Level Alarm
L09 - Piping Leak Detection - Exempt Suction Piping
B00 - Tank External Protection - None
C00 - Pipe Location - No Piping
F00 - Pipe External Protection - None
A00 - Tank Internal Protection - None
D01 - Pipe Type - Steel/Carbon Steel/Iron
K00 - Spill Prevention - None
J02 - Dispenser - Suction Dispenser
G07 - Tank Secondary Containment - Excavation Liner
H99 - Tank Leak Detection - Other